

JOB

DuPont Engineering, Inc.

**4420 S. Arville Street, Suite 1
Las Vegas, NV 89103
(702) 364-5099 Fax (702) 364-1129**

Mel Green Architect, Ltd.
231 West Charleston Boulevard
Suite 10
Las Vegas, Nevada 89102

September 2, 2008

RECEIVED

SEP 03 2008 2 8 8 8 8 . C-08

Attention: Mr. Dylan Yorke

Subject: Geotechnical Investigation Report Update
Commercial Building Addition and Remodel
3100 South Valley View Boulevard
Las Vegas, Nevada

CITY OF LAS VEGAS

DEI No.: 07-0341

Reference: Geotechnical Investigation Report by DuPont Engineering, Inc.
Number 07-0341 dated May 17, 2007

Gentlemen:

This letter is an update to the referenced Geotechnical Investigation Report for the subject project. We visited the site on August 27, 2008 to determine the current conditions. Since the time of our last visit the interior of the building has been gutted. The southwest corner of the structure has been demolished. All pavement has been removed from the site. We understand that another addition is planned for the existing building. An elevator will be installed and the interior of the building will be remodeled and reconfigured.

The Assumed Seismic Use Group (International Building Code, 2006 Edition) is II.


Based on the composition of the on-site soils, the site is classified as Special Inspection Category G-C. Therefore, continuous inspection during grading operations is required.

It is our opinion that all other recommendations provided in the original report for a building addition remain valid for the proposed new construction. If you have questions, please contact us.

Respectfully submitted,
DuPont Engineering, Inc.

David R. DuPont, P.E.
President

DRD/pjb
Dist: 3/Addressee



9/2/08